

产品认证证书

II型自愿认证

证书编号: CQC2014010307745929

发证日期: 2021年08月17日

有效期至: 2031年08月17日

委托人名称	江苏省中仁电气有限公司
及注册地址	江苏省苏州相城经济技术开发区漕湖产业园朝阳工业坊 B3
制造商名称	江苏省中仁电气有限公司
及注册地址	江苏省苏州相城经济技术开发区漕湖产业园朝阳工业坊 B3
生产企业名称	江苏省中仁电气有限公司
及生产地址	江苏省苏州相城经济技术开发区漕湖产业园朝阳工业坊 B3
产品名称和系列、 规格、型号	塑料外壳式断路器 SZRM1-630 ,SZRM3-630 ,SZRM6-630 ;Ue :AC400V(C型、L型、M型) AC400V/690V(H型) ; Ui : 1000V ; Uimp : 8kV ; In : 400A、500A、630A ; C型 : AC400V : Ics=25kA、Icu=35kA ; L型 : AC400V : Ics=35kA、Icu=50kA ; M型 : AC400V : Ics=50kA、Icu=70kA ; H型 : AC400V : Ics=75kA、Icu=100kA , AC690V : Ics=Icu=35kA ; 过电流脱扣器类型 : 热磁式 ; 选择性类别 : A类 ; 极数 : 3P、4P (带三个保护极, N极可开闭) ; 适用于隔离用。
产品标准和技术要求	GB/T 14048.2-2020
认证模式	产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

本证书为变更证书, 证书首次颁发日期: 2020年06月15日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



授权签字人

签发

徐军 谢肇煦

中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C(2) 0092528

产品认证证书

II型自愿认证

证书编号: CQC2014010307745929

第 1 页 共 1 页

本证书及附件应同时使用, 信息查验说明见证书页

纸号: 92528

型号的解释:

SZR M □ - 630 □ / □ 300

(1) (2) (3) (4) (5) (6) (7)

(1): 企业代号

(2): 塑料式外壳断路器

(3): 设计代号(1, 3, 6)

(4): 架等级额定电流(A)

(5): 分段能力级别, C 型: 经济型, L 型: 基本型, M 型: 标准型, H 型: 高分断型

(6): 极数: 3 代表三极, 4 代表四极

(7): 热磁式脱扣器, 无附件



中国质量认证中心



CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2014010307745929

Valid from: Aug.17,2021

Valid until: Aug.17,2031

NAME AND REGISTERED ADDRESS OF THE APPLICANT Jiangsu Zhongren Electric Co.,Ltd.
B3, Chaoyang Industrial Workshop, CaoHu Industrial Park, Xiangcheng Economic and Technological Development Zone, Suzhou, Jiangsu Province, P.R.China

NAME AND REGISTERED ADDRESS OF THE MANUFACTURER Jiangsu Zhongren Electric Co.,Ltd.
B3, Chaoyang Industrial Workshop, CaoHu Industrial Park, Xiangcheng Economic and Technological Development Zone, Suzhou, Jiangsu Province, P.R.China

NAME AND LOCATION OF THE FACTORY Jiangsu Zhongren Electric Co.,Ltd.
B3, Chaoyang Industrial Workshop, CaoHu Industrial Park, Xiangcheng Economic and Technological Development Zone, Suzhou, Jiangsu Province, P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION Moulded Case Circuit-Breaker

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS GB/T 14048.2-2020

TYPE OF CERTIFICATION SCHEMES Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

Date of original issued: Jun.15,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

徐军

SIGNATURE

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

Tel: +86 10 83886666

C(2) 0092528