

产品认证证书

II型自愿认证

证书编号: CQC2017010307933464

发证日期: 2020年06月15日

有效期至: 2031年11月23日

委托人名称 江苏省中仁电气有限公司
及注册地址 苏州相城经济技术开发区漕湖产业园朝阳工业坊 B3

制造商名称 江苏省中仁电气有限公司
及注册地址 苏州相城经济技术开发区漕湖产业园朝阳工业坊 B3

生产企业名称 江苏省中仁电气有限公司
及生产地址 苏州相城经济技术开发区漕湖产业园朝阳工业坊 B3

产品名称和系列、规格、型号 漏电断路器
SZRB2LE-40, SZRB3LE-40, SZRB6LE-40; U_i : 400V; U_{imp} : 4kV; U_e : AC230V;
 I_n : 6A, 10A, 16A, 20A, 25A, 32A, 40A; 瞬时脱扣类型: C 型; $I_{cs}=I_{cn}$: 6kA; $I_{\Delta n}$: 30mA; 额定剩余动作类型: AC 型, 电子式; $I_{\Delta m}$: 500A; 极数: 1P+N (一个保护极, N 极可开闭); 具有隔离功能。

产品标准和技术要求 GB/T16917.1-2014, GB/T16917.22-2008

认证模式 产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



授权签字人

陈昕

签发

谢肇煦

中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C(2) 0126223

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2017010307933464

Valid from: Jun.15,2020

Valid until: Nov.23,2031

**NAME AND REGISTERED
ADDRESS OF THE APPLICANT**

Jiangsu Zhongren Electric Co.,Ltd.
B3, Chaoyang industrial workshop, Cao Hu Industrial Park, Xiangcheng Economic And
Technological Development Zone, Suzhou City

**NAME AND REGISTERED
ADDRESS OF THE
MANUFACTURER**

Jiangsu Zhongren Electric Co.,Ltd.
B3, Chaoyang industrial workshop, Cao Hu Industrial Park, Xiangcheng Economic And
Technological Development Zone, Suzhou City

**NAME AND LOCATION
OF THE FACTORY**

Jiangsu Zhongren Electric Co.,Ltd.
B3, Chaoyang industrial workshop, Cao Hu Industrial Park, Xiangcheng economic and
Technological Development Zone, Suzhou City

**PRODUCT NAME, MODEL
AND SPECIFICATION**

Residual Current Operated Circuit-breaker
SZRB2LE-40,SZRB3LE-40,SZRB6LE-40; Ui:400V;Uimp:4kV;Ue:AC230V;
In:6A,10A,16A,20A,25A,32A,40A; Type of Instantaneous Tripping Current:C;
Ics=Icn:6kA;I_{Δn}:30mA; Rated Residual Operating Type:AC,Electronic Residual Current Tripping
Unit;I_{Δm}:500A; Poles :1P+N(With one protective poles,Switched N pole);Suitable for isolation.
GB/T16917.1-2014,GB/T16917.22-2008

**THE STANDARDS AND
TECHNICAL REQUIREMENTS
FOR THE PRODUCTS**

**TYPE OF CERTIFICATION
SCHEMES**

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.
The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

陈昕

SIGNATURE

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE

